


Application Note AC Drives AN0179 Rev.1.2, 5/22/17

#### This App/Upgrade note applies to AC drives

## Dynamic Braking Resistor Selection Chart (Per Horsepower of Load)

Minimum Dynamic Braking Resistor Power Rating, Per Horsepower, for Various Load Inertia and Number of Stop Per Time, Based on 150% Motor Rated Torque.



The above graph is for **480 Vac** drives. It allows the power dissipation rating of dynamic braking resistors to be determined if the total mechanical inertia at the motor and the number of stops per unit time are known. The graph provides the wattage required per horsepower of motor load with a braking level of **150%** of rated toque and the motor rotating at **1750 RPM**. The resistance for **1 HP**, as indicated on the graph, is **650**  $\Omega$  for AC drives and **193**  $\Omega$  for DC drives (and **500 Vdc** motors). For higher power levels the value of resistance must be decreased in proportion to the horsepower level - for example for **10 HP** AC, **65**  $\Omega$  is needed and the wattage would be ten times that needed for **1 HP**.

# CONTROL TECHNIQUES 7078 Shady Oak Road, Eden Prairie, MN 55344-3505 +1 952 995-8000 www.controltechniques.com



As would be expected, as the number of stops required decreases, the wattage needed is less. However below a particular number the graph indicates a constant power level even if only one stop per hour is required for example. This is due to the energy per stop being too high to allow the safe use of any smaller resistor. The lines on the graph are for various inertia levels per horsepower - so to find the power required for a **50 lb ft**<sup>2</sup> inertia, connected to a **10 HP** motor, one would use the line labeled **5 lb ft**<sup>2</sup> (i.e.: **50 lb ft**<sup>2</sup> /10 HP). Many of the lines increase to a level, and stop. This is because the time for each stop is long enough that no more stops per unit time are possible.

### For example:

For a **50 HP** AC motor and **5 stops / min**, and **250 lb**  $ft^2$ : the inertia **per horsepower** will be **250/50 = 5 Ib**  $ft^2$ . Using the **5 lb**  $ft^2$  line, the power/ HP would be **220W/HP**. For **50 HP**, then, **220x50 = 11,000 W** would be needed.

For inertia values other than those that have associated graph lines other values can be interpolated between given lines. For lower base speed motors the resistance values will be the same, however the required wattage will decrease with the square of the ratio of the base speed to **1750 RPM**. For the above example, if the motor was an **1150 RPM**, the require wattage would be **(1150/1750)<sup>2</sup>(11,000W) = 4750 W**. This will be the case as long as the new calculate value is above the minimum shown on the graph, otherwise the minimum value should be used.

**Resources:** can be found on our website: <u>www.controltechniques.com</u> For help contact techsupport.cta@mail.nidec.com, or call Technical Support at 952-995-8000, 24/7/365

### **CONTROL TECHNIQUES**

7078 Shady Oak Road, Eden Prairie, MN 55344-3505 +1 952 995-8000 www.controltechniques.com